

## Declaration of Conformity for Smoke-Spill Motors

We CMG Pty. Ltd.

of 19 Corporate Avenue

Rowville

Victoria Australia 3178

**ACN** 005 118 114

declare that the product:

Product name Cage induction motor

Series SGAHS, HGAHS

Frame sizes 80 to 315

Ins. Class H

to which this declaration relates is in conformance with the following standard:

Title Number Date of issue

AS 4429

1999

Methods of test and rating requirements for smoke-spill fans

Rating 300°C for 120 minutes

**Application** Dual purpose

This declaration is supported by an independent Test report to AS4429-1999, carried out by CSIRO.

Signed by Jack Gringlas

Title Managing Director

Date 26/04/2007