



# IECEX Certificate of Conformity

## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit [www.iecex.com](http://www.iecex.com)

Certificate No.: **IECEX BAS 14.0008X** Page 1 of 4 Certificate history:  
Status: **Current** Issue No: 4 Issue 3 (2017-09-04)  
Date of Issue: 2021-09-22 Issue 2 (2016-06-02)  
Applicant: **Regal Beloit Australia Pty Limited** Issue 1 (2015-07-30)  
19 Corporate Ave. Issue 0 (2014-06-11)  
Rowville  
VIC 3178  
**Australia**  
Equipment: **Range of PPA/PPC induction motors of frame sizes 80 to 400**  
Optional accessory:  
Type of Protection: **Ex e, Ex tb**  
Marking: **Ex e IIC T3 Gb Tamb (-20°C to +50°C) or,  
Ex tb III C T135°C Db Tamb (-20°C to +50°C) or,  
Ex e IIC T3 Gb Tamb (-20°C to +50°C)  
Ex tb III C T135°C Db**

Approved for issue on behalf of the IECEx  
Certification Body:

**R S Sinclair**

Position:

**Technical Manager**

Signature:  
(for printed version)

  
M POWNEY  
Certification  
Manager

Date:

22/9/2021

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting [www.iecex.com](http://www.iecex.com) or use of this QR Code.



Certificate issued by:

**SGS Baseefa Limited**  
**Rockhead Business Park**  
**Staden Lane**  
**Buxton, Derbyshire, SK17 9RZ**  
**United Kingdom**





# IECEX Certificate of Conformity

Certificate No.: **IECEX BAS 14.0008X**

Page 2 of 4

Date of issue: 2021-09-22

Issue No: 4

Manufacturer: **Regal Beloit Australia Pty Limited**  
19 Corporate Ave.  
Rowville  
VIC 3178  
**Australia**

Additional manufacturing locations: **Regal Beloit New Zealand Limited**  
18 Jomac Place, Avondale, Auckland  
1026  
**New Zealand**

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

## STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

**IEC 60079-0:2011** Explosive atmospheres - Part 0: General requirements  
Edition:6.0

**IEC 60079-31:2013** Explosive atmospheres - Part 31: Equipment dust ignition protection by enclosure "t"  
Edition:2

**IEC 60079-7:2006-07** Explosive atmospheres - Part 7: Equipment protection by increased safety "e"  
Edition:4

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

## TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Reports:

[GB/BAS/ExTR14.0039/00](#)

[GB/BAS/ExTR16.0152/00](#)

Quality Assessment Reports:

[AU/TSA/QAR06.0012/10](#)

[AU/TSA/QAR07.0009/09](#)



# IECEX Certificate of Conformity

Certificate No.: **IECEX BAS 14.0008X**

Page 3 of 4

Date of issue: 2021-09-22

Issue No: 4

## **EQUIPMENT:**

Equipment and systems covered by this Certificate are as follows:

The PPA/PPC range of squirrel cage induction motors is manufactured from cast iron and comprises a main body with a separate bolt-on terminal box. The motors are designed to operate on 3 phase, 100V-1000V and 40-60Hz power systems. Ex e motors may only be used at voltages up to 800V. Motors may be supplied with auxiliary terminal boxes as required for the connection of optional anti-condensation heaters, RTD's and thermistors. Motors are available as foot mounted, flange mounted or foot and flange mounted. The bearings have V-ring seals and the lid of the main terminal box has a nitrile rubber gasket seal, which gives the motors an IP rating of IP66. Electrical connection is via a threaded entry in the main terminal box wall, designed to accommodate either a gland or conduit.

The range of motors is designated as type PPA for Australian output (kW/frame) or type PPC for the EU (kW/frame) and are identical in construction.

See Annex for further details.

## **SPECIFIC CONDITIONS OF USE: YES as shown below:**

1. The equipment may present a potential electrostatic charging hazard; the user instructions shall be followed in order to minimize the risk of electrostatic discharge.
2. For arrangements which include a separate motor driven cooling fan, these shall be tested to verify that the rating of the cooling fan motor is not exceeded.
3. The thermal protection devices, when fitted to the motors with VVVF drives, shall be connected into the motor control circuit in such a manner as to disconnect the source of supply in order to prevent the nominated temperature class from being exceeded. The stator RTDs and thermistors can be connected via a standard industrial controller provided that the controller is located in a safe area.
4. The plug and socket type DXN1 shall not to be used on inverter driven motors above 50/60 hertz.
5. The plug and socket type DXN1 are limited to use within low impact areas.



# IECEX Certificate of Conformity

Certificate No.: **IECEX BAS 14.0008X**

Page 4 of 4

Date of issue: 2021-09-22

Issue No: 4

## DETAILS OF CERTIFICATE CHANGES (for issues 1 and above)

### Variation 4.1

To update QARs only.

File Reference: **21/0601**

### Annex:

[IECEX BAS 14.0008X Annex 1.pdf](#)

**PPA/PPC Range of Induction Motors** with shaft centre heights ranging from 80 to 400mm are manufactured with cast iron frames for horizontal or vertical, foot and/or flange mounting. The flanges may be oversize or undersize as required and the enclosure provides a degree of ingress protection of at least IP55. The range covers 2 pole to 8 pole 3 phase windings for 40 to 120Hz operation at voltages of 100 to 1000V. The range is rated up to 630kW, the largest power ratings being the 4 pole frame size 400LX.

#### Bearing Arrangements

Spigots are machined at either end of the stator frame onto which the machined spigots of cast iron end shields are fitted. The end shields carry the grease lubricated rolling element bearing arrangements which are of ball or roller or angular contact designs. The bearings are covered either by the end shield itself as in smaller frames or by separate bearing covers with appropriate sealing arrangement for ingress protection.

#### Stator

The stator core packs are built from insulated silicon steel laminations which are clamped together. The wound and impregnated stator assembly is secured in the stator frame by an interference fit.

#### Rotor

The rotor core packs built from insulated steel laminations are fitted on to the steel shaft with an interference fit. The rotor cage is of die cast aluminium and is dynamically balanced by the addition of balanced weights secured onto cast studs on the rotor cage. Double shaft extensions or alterations to standard shaft extensions are included in the range. The rotor construction is designed to be compliant with the requirements of Table-4 of IEC60079-7 for any potential risk of air gap sparking with due considerations to risk factors.

#### Terminal Arrangement

The motors are fitted with separate bolt-on cast iron terminal boxes fitted with bolt-on covers incorporating a gasket which is glued to one surface. The position of terminal boxes can be on either side of the motor frame.

Main terminal boxes contain moulded resin/fibre glass terminal blocks incorporating threaded terminal studs to support the winding ends and supply cables with provision for optional auxiliary terminals. Optionally the winding ends may be brought out as extended flying leads via suitably IECEx/ATEX certified conduit fittings for direct connection to the supply terminals. Adequate clearance and creepage distances are provided as required by the standards for Ex e and Ex nA protection for the applicable voltage category.

Auxiliary terminal boxes may be fitted to the main terminal box to facilitate termination of auxiliary devices such as thermistors, anti-condensation heaters and RTDs. IECEx /ATEX certified terminal blocks are used to terminate these auxiliary devices.

Cable glands or conduit fittings shall be suitably IECEx/ATEX certified with IP rating equivalent to or better than that of the equipment rating. Unused cable or conduit entries must be fitted with appropriately certified plugs.

Optional plug and socket type DXN1 DXN2 and DXN6 arrangements may also be used that are covered by their own IECEx certificates IECEx LCI 09.0005X, IECEx LCI 09.0006 and IECEx LCI 09.0007.

#### Ventilation

Various methods of cooling are used including TEFC or TEBC with the blower motor being separately IECEx/ATEX certified. Optionally an IECEx/ATEX certified encoder may be attached to the main motor shaft.

#### Windings

Motors are wound with modified polyester or polyester-imide enamelled copper wires with the winding overhangs suitably insulated and adequately tied in order to compact them and keep the insulation between phases.

#### Use of Variable Voltage Variable Frequency (VVVF) Drives

Ex e motors operating with VVVF drives are to be tested and certified for each rating as a certified pair.

**SGS Baseefa Limited**  
Rockhead Business Park  
Staden lane, Buxton, Derbyshire  
SK17 9RZ  
United Kingdom



ANNEX to IECEx BAS 14.0008X

Issue No. 1

Date: 2016/06/02

Ambient Temperatures

The standard ambient temperature range for Ex e and Ex t motors is -20 to +50°C.

Ingress Protection Rating

The standard ingress protection rating for Ex e motors IP55 and Ex t motors is IP66.

Dielectric Strength Test

All Ex e motors shall be subjected to a routine dielectric strength test in accordance with the requirements of IEC 60079-7